

Karnataka State Fire & Emergency Services Department

Office of the District Fire Officer
Karnataka State Fire & Emergency Services
Yadgire Fire Station , Yadagiri-585201

**C.No:42/DFO/FSR/YDG/2025**

Date:28/11/2025

To,

The Authorized Signatory,
The President

Digvijaya International English Medium School B Gudi
Tq/Shahapur, dist/Yadagiri

Under CGBS Digvijaya Rural development And Charitable Trust ®
Taluk/Shahapur Dist/Yadgiri-585287.

Res Sir,

Sub:- Issuing of "Fire Safety recommendation Certificate" to Digvijaya
International English Medium School B-Gudi Shahapur Under CGBS
digvijaya Rural Development And Charitable Trust ® Taluk/Shahapur
Dist/Yadgiri-585287.

Ref :-1). C.No.11/FSO/FSR/SHPR/2025/425 date:-28-11-2025.

2). Applicant letter date:-22-11-2025.

*_**_**_**_**_**_*

With reference to the subject above cited, the premises of Digvijaya International English Medium School B Gudi Shahapur Under CGBS Digvijaya Rural Development And Charitable Trust ® At/ Shahapur To Sindagi Road, B.Gudi Taluk/Shahapur Dist/Yadgiri-585287 was inspected by Fire Station Officer Shahapur on 28/11/2025 with respect to fire Prevention, Fire Fighting And Evacuation measures and the details are as follows.

ANNEXURE-1**"GROUP-B Educational Buildings**

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01	Name and Address of the Applicant	The President Digvijaya International English Medium School B Gudi Shahapur, Dist/Yadagiri Under CGBS Digvijaya Rural Development And Charitable Trust ® At/ Shahapur To Sindagi Road, B.Gudi Taluk/Shahapur Dist/Yadgiri-585287.
02	Name and Address of the Premises	Digvijaya International English Medium School B Gudi, Tq/Shahapur, Dist/Yadagiri Under CGBS Digvijaya Rural Development And Charitable Trust ® At/

Head Master
Digvijay International
English Medium School
Bheemarayanagudi



MANAGER
Digvijay International
English Medium School
Bheemarayanagudi
Tq. Shahapur Dist. Yadgiri

		Shahapur To Sindagi Road, B.Gudi Taluk/Shahapur Dist/Yadgiri-585287.
03.	Name and Address of the Building Owner	The President To CGBS Digvijaya Rural Development And Charitable Trust ® At/ Shahapur To Sindagi Road, B.Gudi Taluk/Shahapur Dist/Yadgiri-585287.
04.	Number of Building	01
05.	Number of Floors	Ground floor only
06.	Floor-wise details of Occupancy:-	
	Ground Floor	Class Room-13 no's, Staff Room-01 no, Administration Room-01 no, Waiting Room-01 no, Principal Room-01 no, Computer Lab-01 no, First aid room-01 no, Activity Room-01 no, Dance Room-01 No, Room-01 no, Ladies Room-01 no, Library Room-01 no, PCM Lab-01 no, Maths Lab-01 no, Craft Room-01 No.
07.	Height of the building	04.50 mtrs
08.	Site area	7992.50 sq.mtrs
09.	Built-up area of each floor:-	
	Ground Floor	2160.00 sq.mtrs
10.	Total Built-up area	2160.00 sq.mtrs
11.	Surrounding properties:-	
	East (side)	Agricultural land.
	West (side)	Agricultural land.
	North (Front)	06.00 Service road
	South(Rear)	Agricultural land.
12.	Open Space all around the building	
	East (side)	09.00 Mtrs.
	West (side)	06.50Mtrs.
	North (Front)	46.00 Mtrs.
	South(Rear)	06.50 Mtrs.
	Allowed Setbacks (open space) should be maintained free from further obstruction/construction.	

On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

Sl. No (01)	Details (02)	Existing (03)	Recommendations (04)
01	Accessibility to	The premise is accessible from	

MANAGER

 Digvijay International
 English Medium School
 Bhojpur, Bhojpur
 Tal. Shahapur Dist. Y.

FIRE OFFICE

 Head Master
 Digvijay International
 English Medium School

	the premises	06.00 mtrs road on Northern side	
02.	Number of Entrances	01 no. Of Entrance/Exits with 06.00 Mtrs width.	--
03.	Portable Extinguishers	Not Provided	A. One CO2 type fire extinguisher of 4.5 kgs capacity should be provided near each electrical panel board & electrical room. B. One mechanical foam extinguisher of 09 ltr capacity & one ABC type extinguisher of 06 kgs capacity should be provided near the diesel generator. C. One DCP extinguisher of 04 kg capacity should be provided in the kitchen if provided for the purpose of Mid-Day Meal. D. One ABC type fire extinguisher of 06 kgs capacity should be located as to be available within 15. Mtr radius. E. All the extinguishers suggested above should be with BIS markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically.
04.	Escape routes	Not Marked	Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.
05.	Fire Order (Fire safety plans)	Not Displayed	A notice board have been indicated the action to be taken by the employees in case of any emergency should be displayed with the telephone numbers of Shahapur fire station i,e 08479-224101 & 112 and the telephone nos nearest ambulance services and police station.
06.	No Smoking board	Not Displayed	COPTA Sec-4 direction of No Smoking area , smoking here is an offence board should be

			written in English & Kannada both languages shall be prominently displayed at inside the entry/exit of the each floor.
07.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore / Regional training center.
08.	<u>Fire Precautionary Measures</u> A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises. B:- Accumulation of combustible waste in and around the premises should be avoided. C:- The Exit ways shall be always kept clear without any obstruction. D:- Liquefied petroleum gas should not be stored in the building. E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction. F:- During the class hours the class room door shall not be locked from inside to out side. G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14 th of every year by conducting Fire Safety drills with co-ordination with the fire services department.		


Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Recommendation" to "Digvijaya International English Medium School B Gudi Shahapur. Under CGBS Digvijaya Rural Development And Charitable Trust @ At/ Shahapur To Sindagi Road, B.Gudi Taluk/Shahapur Dist/Yadgiri-585287.subjected to condition and compliance of the above recommendations in column -4 of serial -B within 03 months and compliance to the undersigned.


This "Fire Safety Recommendation" is valid for only one year from the date of issue and is renewable.

Copy to

- 1). Fire Station Officer
Fire Station Shahapur

Yours Faithfully


District Fire Officer 22/11/2025
Karnataka Fire & Emergency Services
Yadgir Dist, Yadagiri - 585281


Head Master
Digvijay International
English Medium School
Bheemaranagudi
Tq.Shahapur Dt.Yadgir


MANAGER
Digvijay International
English Medium School
Bheemaranagudi
Tq. Shahapur Dist.Yadgir